

Power supply equipment capacity and connected cables

Model number	YD-60GA1	YD-80GA1
Equipment capacity	Rated input or higher is required at the input terminal section. (Power supply should be connected to the input terminal section)	
Fuse (Type B)	120 A	150 A
Breaker (No-fuse breaker)	150 A	200 A
Input side cable	38 mm ² or more (for M8)	38 mm ² or more (for M10)
Ground cable	14 mm ² or more	

Output (Base) side cable

Output current	600A	800A
Cable diameter	100 mm ² or more (for M8)	125 mm ² or more (for M10)